

STATE OF HAWAII REQUEST FOR EMERGENCY PROCUREMENT

TO: Chief Procurement Officer

FROM: Leahi Hospital
(Department/Division/Agency)

Pursuant to §103D-307, HRS and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for this emergency procurement.

Date: <u>2/10/05</u>	After the fact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Nature of the Emergency: Replace water bell in the fire sprinkler system. If this component is not replaced, audible alarm will not sound, endangering personnel in the area. The defective bell was discovered during the sprinkler inspection on 2/10/05.	

Vendor: <u>SimplexGrinnell LP</u>	Amount: <u>\$600.00</u>
--------------------------------------	----------------------------

Description of goods, services, or construction to be purchased:
Labor and materials to replace the defective water bell.

Reason for Vendor Selection:
Selected vendor is familiar with our system, conducted the inspection, and found the defective component. Vendor also has the required liability insurance coverage.

Direct questions to: Darrell Chun Fat Phone: 221-9028

I certify that the information provided above is, to the best of my knowledge, true and correct.

Vincent Lee 2/17/05
 Department Head or Designee Date
Oahu Regional CEO
 Title (If other than Department Head)

Chief Procurement Officer's Comments:

APPROVED DISAPPROVED

[Signature] 02/15/05
 Chief Procurement Officer Date